
	<b>CONSTRUCTION OF 12 BUILDING STAFF ACCOMODATION VILLAGE</b>	<b>SAMPLE TAG</b>	
				Reference No.	069LD-MAK-TAG-CIV-00G0163
Originator of Submittal	<b>M.A. ALKHARAFI &amp; SONS</b>		PLOT-1 (SD_63), PLOT-2 (SD_62), PLOT-3 (SD_61), PLOT-4 (SD_60) AT DLC STAFF VILLAGE, DUBAI SOUTH	Rev. No	02
Requested by				Date Submitted	19 . 06 . 2020

**MATERIAL DETAIL**

Item Description	Suspended Ceiling		
Area of Use	False Ceiling Works		
Contractor Statement	We certify that the material submitted herewith is a specimen of the material which is to be used in the areas described above, and in compliance with the contract drawings and specifications except as otherwise stated in the related Alternative Material Submittal Form. We undertake full responsibility to ensure that the material delivered at site is the same as the approved sample.		
Contractor's Authorized Representative Name	Mr. Moataz Al Hawary		

**ENGINEER'S COMMENTS**

Date Received by Engineer document controller and signature	Incoming Ref. No.
<p>- WEDGE ANCHOR SAMPLE TO BE PROVIDED</p> <p>- STANDARD CALCIUM SILICATE RAL COLOURS TO BE PROVIDED FOR SELECTION &amp; APPROVAL</p> <p>- TRIM ACCESSORIES FOR T-GRID SYSTEM TO BE CLOSEST MATCH COLOUR TO CEILING TILES.</p> <p>- MOCK - UP TO BE PROVIDED FOR APPROVAL.</p> <p style="text-align: right;"><i>[Signature]</i> 10/04/19</p>	