



Originator
Submittal

M.A. HAWARY

COMPLETION

OFFICE BUILDING AT PLOT NO 3-1-1, TUSA, AREA SOUTH (PLOT 7), QURAI, UAE

14/04/2020

Item	Description	Discipline	List of Enclosure
Specifications Reference	SEC-05		(Tick as Applicable)
BOQ Reference		<input type="checkbox"/> Infrastructure <input type="checkbox"/> Architectural <input type="checkbox"/> Structural <input type="checkbox"/> Mechanical <input type="checkbox"/> Electrical <input type="checkbox"/> HVAC	<input type="checkbox"/> Prequalification Documents <input type="checkbox"/> Trade License <input type="checkbox"/> Vendor's Technical Literature <input type="checkbox"/> List of Previous Projects Done <input type="checkbox"/> Compliance Statement Sheet (*) <input type="checkbox"/> Method Statement
Drawing Reference			
Material Specified	SUSPENDED CEILING SYSTEM (Material submittal & Pre-qualification)		
Material Proposed	SUSPENDED CEILING SYSTEM (Material submittal & Pre-qualification)	<input type="checkbox"/> Plumbing <input type="checkbox"/> Finishes	<input type="checkbox"/> Previous Test Results <input type="checkbox"/> Copy of the Related Specifications
Supplier / Source	SOURCE:-Knauf / Gyproc/BORAL/Technocac/AWI SUB CONTRACTOR :-VISION MAINTENANCE AND DECOR	<input type="checkbox"/> External Works	<input type="checkbox"/> Samples
Address of Manufacturer	UAE	<input type="checkbox"/> Civil Works <input type="checkbox"/> Landscaping	<input type="checkbox"/> App. Drawings (if applicable) <input type="checkbox"/> Others (Draw. Warranty)
Contractor Remarks	As per Vendor List		
Contractor's Authorized Representative Name	Eng. Moadaz Al Hawary (P.M)	Signature	Stamp

TARGET ENGINEERING CONSULTANT
RECEIVED
 Date: 08 APRIL 2020



ENGINEER'S COMMENTS

Incoming Ref. No. , if applicable (to be filled by RE)

- No objection For the proposed manufacturer & subcontractor For the suspended ceiling material, subject to comply with the following comments,

- Provide mock-up on site For final approval.
- compliance with project spec & authority requirement,
- warranty to be in accordance with contract terms & conditions.
- submit shop drawing & Method Statement For review & approval.
- Handling storage & application should be as per manufacturer's recommendation.
- all materials to be delivered at site should be in original packaging & containers or bundles bearing brand name & identification of the manufacturer's or supplier.
- subject to client for final approval.

Continued on next page..

ENGINEER'S APPROVAL STATUS

Code 1
 Code 2
 Code 3
 Code 4
 For Information Only

RE Technical Team Review Name and Position

Mohamed Hamad

Engineer's Authorized Representative Name



Signature, Date and Stamp

14/4/20

Signature, Date and Stamp

CONTRACTOR RECEIVED SIGNATURE

Date _____ Signature and Stamp _____

DOCUMENT STATUS

- Code 1 - Approved.
- Code 2 - Approved as noted, work may proceed subject to incorporation of comments indicated.
- Code 3 - Revise & resubmit.
- Code 4 - Rejected

Any amendments to this form should be approved by the Engineer prior to use by the contractor.