

**DWC- Emaar South Development DWC Construction of Urbana II Stacked
Townhouse GA-05**

The Engineer: **U+A**

CONTRACT:

Package No:

MATERIAL SUBMITTAL

Date : **23-DEC-2020**

Submittal No. : **EMR-ESD-MAT-CIV-075**

To The Engineer : **Mr. Abdul Hameed Al Qadhi**

New Submittal : **Rev 00**

Resubmittal :

MATERIAL DESCRIPTION

AS SPECIFICATION

**False Ceiling Works
(As per attached material list)**

ALTERNATIVE

Area of Use: **Ceiling**

Drawing Ref.

B.O.Q. Ref. No.

Specification Ref. **Sect-092500 Gypsum Board
Sect-083100 Access Panels**

Standards , BS , DIN :

ASTM A 82



(Attach all relevant technical literature marked to identify relevant descriptions , current test certificate , samples etc.)

MANUFACTURER / SUPPLIER

Company Name : **Al Waseef Group/Kanuf/Hilti**
VISION MANITENANCE AND DECOR

DELIVERY

Country of Origin : **China**

Availability **Locally Manufactured** []

Address : **VISION MANITENANCE AND DECOR**

C.C.A.S.G. Manufactured []

P.O Box 21425, Dubai,UAE

Manufacture **Production Period** [___]

Tel: 97142584811 Fax: 97142584812

Delivery Ex-Works [___]

Local Agent : **VISION MANITENANCE AND DECOR**

Total delivery time [___]

Overland []

Sea Freight []

Total Freight []

PROGRAMME **Date material required on site** _____
Estimated date of arrival on site _____

Engineer's Comments :

- TO COMPLY W/ PROJECT SPECIFICATIONS AND APPROVED METHOD STATEMENTS.
- THE MAIN CONTRACTOR TO ENSURE SATISFACTORY PERFORMANCE BY THE SUB CONTRACTOR.
- ACCESS PANEL TRIMS TO MATCH CEILING PAINT COLOR (RAL9016)
- RELEVANT INSPECTION REQUESTS TO BE ISSUED PRIOR TO ACTIVITY COMMENCEMENT & CLOSEUP.
- TO BE COORDINATED W/ MEP.

Approval Status

APPROVED [] APPROVED AS NOTED []


REJECTED []

RESUBMIT AS NOTED []

RESIDENT ENGINEER

Abdul Hameed

PROJECT MANAGER



Distribution:

Head Office Client