





The Engineer:  Member of the SNC-Lavalin Group	The Employer: 	The Contractor:  Construction Group since 1972
5183550 - Reflection A&B Towers, Shams, Reem Island Abu Dhabi		




<h2 style="margin: 0;">Material Submittal</h2>	Ref. No. SAD-B3-FIB-AR-MSU-00268 Rev. No. 02
--	---


Originator of Submittal :	Rahaf Elsulh	Date:	19/03/2020
Authorised Sign :		Reqd. By:	7

	Material Detail	List of Enclosure
Item Description	Gypsum Board for Partition	(Tick the Related Box)
Specs. Reference	092900	<input checked="" type="checkbox"/> Vendor's Technical Literature
BOQ Reference	Bill Nr 2	<input checked="" type="checkbox"/> Compliance Statement
Drwg. Reference	SAD-B3-PW-AR-TA-GF-01101 / 05060	<input checked="" type="checkbox"/> Previous Test Results
Material Specified	Gypsum Board for Partition	<input checked="" type="checkbox"/> Copy of the Related Specs.
Material Proposed	Gypsum Board for Partition	<input type="checkbox"/> Samples with Sample Tag
Manufacturer / Supplier	KNAUF // VISION MANITENANCE AND DECOR	<input checked="" type="checkbox"/> List of Previous Projects Done
Remarks	Behind Core Wall, Generator Room & Precast Panel	<input type="checkbox"/> Others (Specify):



Contractor Statement: We certify that the material submitted herewith has been reviewed in details and is in compliance with the contract drawings and specifications except as otherwise stated hereabove.

Contractor Sign: 	Date: 19/03/2020
ATKINS Received Sign:	Date:
	Ref.No 5183550/R11- 2359

ATKINS Engineer's Comments: *Architect:- Following documents to be submitted vide separate submittal.*
 1) Civil Defense Certificate for Generator Room lining system
 2) Structural Calculation for Generator Room lining System with 4.5 meter height & 200 Pa lateral load

Reviewed By: 	Date: 31/03/20
--	----------------

ATKINS Resident Engineer's Comments:	<input type="checkbox"/> Code A - Approved <input checked="" type="checkbox"/> Code B - Approved As Noted, Resubmit <input type="checkbox"/> Code C - Not Approved, Resubmit <input type="checkbox"/> Code D - Information, Record <input type="checkbox"/> Code E - Incomplete, Resubmit
---	---

ATKINS RE Sign: 	Date: 
	Ref.No 5183550/R10- 2288
Contractor Received Sign:	Date:

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the contract requirement and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents.